





Delhi Jal Board

DELHI JAL BOARD  
(GOVT. OF N.C.T. DELHI)  
QUALITY CONTROL ZONAL LABORATORY (SOUTH)  
WATER WORKS OKHLA DELHI-110025



Licence No- CRO/QM/L-8004290 IS/ISO 9001:2015



Ref. A.C.W.A.(South):- Paid/2022-23/P74-75/Challan no 219 Dt 21.10.2022

S. No 8035

Date: 01.11.2022

M/S SANT NIRANKARI PUBLIC SCHOOL  
OPP GALI NO 15, GOVIND PURI  
NEW DELHI-110019

Date of Sample collection :- 27.10.2022

| S.No | Characteristics                          | Unit                 | Acceptable Limit | Permissible Limit | Test Method     | SINTEX TANK ON THE ROOF OF SCHOOL | TAP DRINKING POINT NEAR LIFT G/FLOOR |
|------|--|----------------------|------------------|-------------------|-----------------|-----------------------------------|--------------------------------------|
| 1.   | Clarity                                  | Unit                 | 5                | 15                | IS 3025 Part-4  | Clear                             | Clear                                |
| 2.   | Odour                                    | ---                  | Agreeable        | Agreeable         | IS 3025 Part-5  | Agreeable                         | Agreeable                            |
| 3.   | Turbidity                                | NTU                  | 1                | 5                 | IS 3025 Part-10 | 1.10                              | 1.07                                 |
| 4.   | pH Value                                 | ---                  | 6.5-8.5          | No relaxation     | IS 3025 Part-11 | 7.3                               | 7.4                                  |
| 5.   | Conductivity                             | µmho/cm <sup>2</sup> | ---              | ---               | ---             | 405                               | 407                                  |
| 6.   | Total Dissolved Solids                   | mg/L                 | 500              | 2000              | IS 3025 Part-16 | 263                               | 265                                  |
| 1.   | Phenolphthalein Alkalinity               | mg/L                 | ---              | ---               | ---             | NIL                               | NIL                                  |
| 2.   | Total Alkalinity (as CaCO <sub>3</sub> ) | mg/L                 | 200              | 600               | IS 3025 Part-23 | 120                               | 118                                  |
| 3.   | Total Hardness (as CaCO <sub>3</sub> )   | mg/L                 | 260              | 600               | IS 3025 Part-21 | 154                               | 150                                  |
| 4.   | Carbonate hardness                       | mg/L                 | ---              | ---               | ---             | 120                               | 118                                  |
| 5.   | Non- Carbonate Hardness                  | mg/L                 | ---              | ---               | ---             | 34                                | 52                                   |
| 6.   | Calcium Hardness                         | mg/L                 | ---              | ---               | ---             | 116                               | 106                                  |
| 7.   | Magnesium Hardness                       | mg/L                 | ---              | ---               | ---             | 38                                | 44                                   |
| 8.   | Ammonia (as Total N)                     | mg/L                 | 0.5              | No relaxation     | IS 3025 Part-34 | ND                                | ND                                   |
| 9.   | Nitrite (as N)                           | mg/L                 | ---              | ---               | ---             | ND                                | ND                                   |
| 10.  | Nitrate                                  | Mg/L                 | ---              | 45.0              | IS 3025 Part-34 | 4.65                              | 3.95                                 |
| 11.  | Sulphate (as SO <sub>4</sub> )           | mg/L                 | 200              | 400               | IS 3025 Part-24 | 46                                | 46                                   |
| 12.  | Chloride (as Cl)                         | mg/L                 | 250              | 1000              | IS 3025 Part-40 | 36                                | 36                                   |
| 13.  | Iron                                     | Mg/L                 | ---              | 1.0               | IS 3025 Part-53 | 0.16                              | 0.16                                 |
| 14.  | Fluoride                                 | mg/L                 | 1.5              | 1.5               | IS 3025 Part-60 | 0.2                               | 0.3                                  |
| 15.  | Calcium (as Ca)                          | mg/L                 | 75               | 200               | IS 3025 Part-57 | 46.4                              | 42.4                                 |
| 16.  | Magnesium (as Mg)                        | mg/L                 | 30               | 100               | IS 3025 Part-46 | 9.12                              | 10.56                                |
| 17.  | Free Residual Chlorine                   | mg/L                 | 0.2              | 1                 | IS 3025 Part-26 | NIL                               | NIL                                  |

REMARKS :- AS PER BIS-10500:2012 On the basis of tested parameters the above both sample result are within permissible limit, Subject to Bacteriological satisfactory report.

Assistant Chief Water Analyst  
Delhi Jal Board (A Govt. of Delhi)  
Zonal Laboratory (South)  
W.W. Okhla New Delhi - 110 025

Copy to:-  
1 CWA(W&S)-III  
2 Office Copy

CHEMIST

HOS

VICE PRINCIPAL  
SANT NIRANKARI PUBLIC SCHOOL  
GOVIND PURI, NEW DELHI-110019  
M.NO: 09560848789

HOS  
VICE PRINCIPAL  
SANT NIRANKARI PUBLIC SCHOOL  
GOVIND PURI, NEW DELHI-110019  
M.NO: 09560848789

Manager  
Sant Nirankari Public School  
Govind Puri, New Delhi - 110019  
Ph. No.: 26284380



"STOP CORONA VIRUS-Wash Your Hand/Wear Mask/Maintain Social Distance"



Delhi Jal Board

DELHI JAL BOARD  
(GOVT. OF N.C.T. DELHI)  
QUALITY CONTROL ZONAL LABORATORY (SOUTH)  
WATER WORKS OKHLA DELHI-110025



Licence No- CRO/QM/L-8004290 IS/ISO 9001:2015



Dated:01.11.2022

No. DIB/DTQC/ CWA (W&S)III / ACWA (south)/ Paid/ Bact. /2022-2023/89-90/27.10.2022

Bacteriological Analysis Report as per IS 10500:2012

To Sant Nirankari Public School

Gali No – 15, Govindpuri

New Delhi -110019

Party Ref.No./Date: SNPS/GP/2022-2023/131/Dt:20.10.2022

Deptt.Challan No. /date: 219/21.10.2022

Dt.of sample collection: 27.10.2022

No. of Sample: Two(02)

Collected by: Name- Sh. V.P Singh  
Desig.- Bacteriologist

| SL.No. | Particulars  | Clarity | Residual chlorine | Total coliform/<br>E.coli in 100 ml sample |
|--------|--|---------|-------------------|--|
| 1.     | Syntex Tank in the roof of Sant Nirankari Public School Govindpuri   | Clear   | NIL               | 0  |
| 2.     | Tap Drinking Point Near lift Sant Nirankari Public School Govindpuri | Clear   | NIL               | 0  |

RESULT:- Collected water sample(s) as mentioned above at Sr.No. 1&2 were found bacteriological satisfactory, hence the water/source is fit for drinking/recreational purpose subject to satisfactory attached Physical-Chemical Analysis report also.

ACWA (SOUTH)

Assistant Chief W  
Delhi Jal Board (A  
Zonal Laboratory (S  
W.W. Okhla New Delhi - 110025

HOS  
VICE PRINCIPAL  
SANT NIRANKARI PUBLIC SCHOOL  
GOVIND PURI, NEW DELHI-110019  
M.NO: 09560848789

BACTERIOLOGIST(SOUTH)

ASSTT/BACT.

HOS  
VICE PRINCIPAL  
SANT NIRANKARI PUBLIC SCHOOL  
GOVIND PURI, NEW DELHI-110019  
M.NO: 09560848789

Manager  
Sant Nirankari Public School  
Govind Puri, New Delhi - 110019  
Ph.No.: 26284380